

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:31 am

PWS ID: UTAH01016 **Name:** HI-LO ESTATES

Legal Contact: HI-LO ESTATES **Rating:** Not Approved
LINDA MESINAR **Rating Date:** 02/03/2010

Address: 3990 Wainscot Court **Activity Status:** Active
LAS VEGAS, NV 89147

Phone Number: 702-363-7602

City Served (Area):

County: BEAVER COUNTY

System Type: Non-community **Last Inv Update:** 03/31/2011 **Avg Daily Prod:**

Activity Status Cd: Active **Last Snty Srv Dt:** 06/29/2010 **Total Dsgn Cap:**

Population: 48 **Surveyor:** STEVE BRENCHELY **Total Emerg Cap:**

Oper Period: 5/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	MESINAR, LINDA		702-363-7602	435-590-2606	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	28
			28 Total Svc Connections

Storage

Total Storage: 11,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE TANK	Ground	11,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	HI LO ESTATES BOOSTER PUMP	P		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	HILO EST. WELL	Active	WL		7.33 GPM	6 GPM	Yes	GW	Seasonal	5/1 to 9/30	

*Reports measured flow for wells, approved design capacity for all other sources.